

132



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No. F6/DFS/MS/School/2023/SZ/ 162

Dated: 06/04/23

To,

The Manager,
Indraprastha School, D-18,
Nawada, Uttam Nagar, New Delhi-110059.

Sub: - Regarding issue of "Fire Safety Certificate" from fire safety point of view in r/o M/s
Indraprastha School, D-18, Nawada, Uttam Nagar, New Delhi-110059.

Sir,

Please refer to your letter Nil dated 20/03/2023 on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the school building to verify the fire safety arrangements in accordance with the rules. At the time of inspection Sh. Siddhant Gahlot was present and it was observed that the building is comprised of ground plus two upper floors and have following shortcomings:-

1. Fire extinguishers provided but not functional.
2. First aid hose reel found removed.
3. Fire pump having 450 lpm provided but not functional.
4. Over head water storage tank 3000 liters provided in place of 10,000 liters.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk & liability of the owner/occupier. The Licensing Authority/Statutory Authority may be take suitable necessary action as deemed fit.

Yours, faithfully

(A. Garg)

Director

Delhi Fire Service

2023

Copy to:-

1. Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi-110054.