



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आज़ादी का
अमृत महोत्सव

No.F6/DFS/MS/School/SZ/2023/ 154

Dated: 03/04/2023

To

The Principal,
Ram Chander Memorial Public School,
GC -74, Pul Prahladpur,
New Delhi-44.

Sub:- Regarding renewal of Fire Safety Certificate in respect of **Ram Chander Memorial Public School located at GC -74, Pul Prahladpur, New Delhi-44.**

Sir,

With reference to the outdoor diary no. 10686 dated 31.01.2023 on the subject cited above, it is informed that the school building was inspected by Assistant Divisional Officer (M. Road) from this department on 18.03.2023 in the presence of Mr. Kuldeep Singh (Principal) and it was observed that the building which was earlier comprised of basement, ground + 03 upper floor is now comprised of basement, ground + 04 upper floors & school is running on Ground + 04 upper floors. Hence is a case addition/alteration. The fire and life safety requirements are therefore applicable as prescribed in Unified Building Byelaws 2016 and National Building Code 2016 as per which following shortcomings were observed:-

1. First aid hose reels found non functional.
2. Fire pump found non functional.
3. Exit signages found removed.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully


(Atul Garg)
Director

Delhi Fire Service

Copy to:-

1. The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony, New Delhi-24.
2. The Executive Engineer (Bldg.), South Delhi Municipal Corporation, 8th floor, SPM Civic Centre, Minto Road, Delhi-02: to measure the height of the building under intimation to this department.