

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001**

C114

N 6/DFS/MS/School/NDZ/2023 / 153

Dated: 03/04/2023

To

The Principal,  
H.M.D.A.V. Senior Secondary School,  
Darya Ganj, New Delhi -02.

**Sub:-** Regarding renewal of Fire Safety Certificate in r/o **H.M.D.A.V. Public Primary School** located at **Darya Ganj, New Delhi -02.**

Sir,

This has reference to letter no. 4719/23 dated 03.02.2023 received in this department, on the subject cited above. In this connection, this is to inform you that the school building was inspected by officer concerned of this department on 22.03.2023 in the presence of (Principal). During the inspection, following shortcoming is observed:-

1. Fire extinguishers are not adequately provided (required as per IS 2190).

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

  
(Atul Garg)  
Director  
Delhi Fire Service  
Tel: 0112341400  
o/c  
3/13

**Copy to:-**

The Director of Education,  
Govt. of NCT of Delhi, Old Secretariat, Delhi.