

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/2023/SZ/ 698

Dated 06/04/2023

To

The Joint Commissioner of Police, Lic/Branch,
1st Floor, P S Defence Colony,
New Delhi 110049

Sub Issuance of FSC in r/o M/s Fun City (City Max Hotels) Pvt Ltd, Video Game Parlour situated at 3rd Floor, Ambience Mall, Plot No. 2, Nelson Mandela Marg, Vasant Kunj, New Delhi-110070.


Sir,

This has reference to your letter no 66-70/Joint C P/Lic (Amst.) dated 08/02/2023 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 20/03/2023 in the presence of Mr. Pankaj Kumar (Manager) to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. Hose reel nozzles found removed.
2. Fire hose Cabinet (FHC) is not accessible encroachment and fixing of video game machine in the pathway which need to be removed.
3. Internal hydrant not working.
4. Exit Sign found removed.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

9/4