



No.F6/DFS/MS/School/SZ/2023/155

Dated: 03/04/2023

To

The Principal,
Manav Mangal Public School,
M.B. Road, Pul Pehladpur, New Delhi-44.

Sub:- Regarding renewal of Fire Safety Certificate in respect of **Manav Mangal Public School located at M.B. Road, Pul Pehladpur, New Delhi-44.**

Sir,

This has reference to your letter no. MMPS/Fire/NOC/2022 dated 14.07.2022 on the subject cited above, it is informed that the school building was inspected by Assistant Divisional Officer (M. Road) from this department on 18.03.2023 in the presence of Manager and it was observed that the building is comprised of Ground + 4 upper floors (school is running at G+ 3 upper floors & 4th floors used as a residence). During the inspection following shortcomings was observed:-

1. Hose reel & down comer system found non functional.
2. Fire pump found non functional.
3. Exit sinages found removed.

In view of above shortcomings, the application renewal of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(Atul Garg)
Director

Delhi Fire Service

03/04/23

Copy to:-

1. The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony, New Delhi-24.