



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2023/ 684

Dated 10/04/2023

To,

Dr. S. K. Narang
Narang Eye Institute
B-8, Derawal Nagar, Model Town,
New Delhi-110009.

Sub:- issuance of fire safety certificate in r/o Narang Eye Institute located at B-8, Derawal Nagar, Model Town, New delhi-110009.

Sir,

This has reference to your letter no. nil dated 27.02.2023 on the subject cited above. In this connection this is to inform you the above mentioned site was visited by the officer concerned of this department on 17.03.2023 to verify the fire safety arrangements installed in the building. At the time of inspection Mr. Subhash Sharma (Admin) was also present at site. During the course of the inspection it is observed that the building is comprised of ground & 03 upper floors with porta cabin at terrace. Your request for FSC is rejected under Rule 35 (3) due to following shortcomings.

1. All doors size are 80cm provided against the requirements of 1.20m.
2. The single staircase of 90cm is provided against the required width of 1.25m. One additional staircase having width of 1.25m is also required from ground to upper floors.
3. Electrical driven fire pump capacity of 2280lpm., Diesel engine pump 2280lpm & jockey pump 180lpm not provided.
4. Underground water tank of 50,000 ltrs not provided.
5. Draw off connection and fire service inlet is not provided

Keeping in view of above Fire Safety Certificate cannot be considered at this stage. You may apply again on form 'I' as stipulated in sub rule (2) 35 of rules, DFS Rules 2010 after compliance of the shortcoming mention above. The link for forms is as under available on <http://delhi.gov.in/wps/wcm/connect/doit fire/FIRE/Home/Forms>.

Yours faithfully


Atul Garg
Director
Ph: 011-23414000
JCP