

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

O. F-6/DFS/MS/EH/2023/SZ/ 171

Dated 06/04/2023

To

The Dy Health Officer,
Public Health Department, MCD,
Aurobindo Marg, Green Park,
New Delhi 110016.

Sub: - Regarding issuance of fire safety certificate in r/o M/s Bonne FOI 65 (A Unit of Rosebeer Hospitality Pvt Ltd.) Plot No 42, Ground Floor Community Centre, East of Kailash, New Delhi 110065.

Sir,

This has reference to with MHA Portal ID. 2022101118911 dated 17/03/2023 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 24/03/2023 in the presence of Mr. Parmod to verify the fire safety measures installed in the building and observed that restaurant running at Ground Floor only. During inspection, following points were observed.

1. The opening of basement is through restaurant sealing area which needs be segregated at ground level.
2. First aid hose reel hose provided but found not working.
3. Terrace level pumps and overhead tanks are not accessible. Hence could not be verified.
4. Exit signage not provided at some places.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to

1. The Joint Commissioner of Police (Lic/Branch) 1st Floor P/S Defence Colony, New Delhi (Ref MHA Portal ID. 2022101118911 dated 17/03/2023)