

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/SCHOOL/WZ/2023 /171

Dated: 11/04/2023

To

The Principal,  
 M. C. Primary Co-ed. School,  
 Ashok Park Ext.,  
 New Delhi- 110026.

**Sub: - Regarding issuance of Fire Safety Certificate in r/o M. C. Primary Co-Ed. School Located at Ashok Park Ext, New Delhi - 110026.**

Sir,

Please refer to your Letter no. nil, Outdoor diary No. 10516 dated: - 27/01/2023 on the subject cited above. In this connection, it is to inform you that the said building was re-inspected by the officer concerned of this department on 20/03/2023 in presence of Smt. Anju (Principal) to check the shortcomings already issued by this department vide letter no. F6/DFS/MS/WZ/2019/2263 dated 23/04/2019.

The Status of shortcomings are as under:-

S. no.	Shortcomings	Status
1.	Width of exit door is 82cm against required width of 1m	Not Rectified
2.	Hydrant & Hose reel hose found not provided.	Not Rectified
3.	Terrace pump of 450 LPM found not provided.	Not Rectified
4.	Terrace tank of 10,000 ltr capacity found not provided	Not Rectified

In view of above Shortcomings the application for issuance of Fire safety Certificate is rejected. The occupancy of the Building/ premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier. The statutory authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Yours faithfully

  
 (Atul Garg)  
 Director

Copy To: -

1. The Director, Directorate of Education, old secretariat, Delhi.

1/c  
 05/04/2023