

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001**

e/13

No. F6/DFS/MS/School/WZ/2023/ 176

Dated: 11/04/2023

To,

The Principal,  
Nigam Prathiba Vidyalaya,  
Satyawati Nagar,  
New Delhi-110052.

**Sub: - Regarding Issuance of Fire Safety Certificate in r/o M.C Primary School (School ID - 1556150), located at Block No. -18, Moti Nagar, New Delhi-110015**

Sir,

Please refer to your Letter No. MCPS/MNW/7/2022 dated 26/12/2022 on the subject cited above. In this connection, it is to inform you that the said building/premises was inspected by the officer concerned of this department on 13/03/2023 in presence of Smt. Manju Ranjan (Incharge) to see the functioning of fire safety equipments provided in the building.

During inspection, it has been observed that the above said school is running at Ground plus two upper floors in a building is comprised of Ground plus Two upper floors. However, the following Shortcomings were observed.


1. First Hose reels are provided but not functional.
2. Terrace fire pump of 450 lpm is provided but not functional.
3. Overhead water storage tank capacity 10,000 ltrs is provided but found empty.
4. Exit signage's are found removed.

In view of above Shortcomings the application for Issuance of Fire safety Certificate is rejected. The occupancy of the Building/ premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier. The educational authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Yours Faithfully,

  
(Atul Karg)  
Director

Copy to: -

  
30/3/2023

1. The Director, Directorate of Education, old secretariat, Delhi.