

4/59



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No.F6/DFS/MS/School/SZ/2023/ 177

Dated: 11/04/2023

To

The Principal,
Modern Public School,
GD-6, Pul Prahlad Pur, New Delhi-44.

Sub:- Regarding renewal of Fire Safety Certificate in respect of **Modern Public School located at GD-6, Pul Prahlad Pur, New Delhi-44.**

Sir,

With reference to your letter no. MPS/2022 dated 19.10.2023 on the subject cited above, it is informed that the school building was inspected by Assistant Divisional Officer (M. Road) from this department on 31.03.2023 in the presence of Mrs. Geeta Sharma (HOS) and it was observed that the building which was earlier comprised of basement & ground floor only is now comprised of basement & ground + 01 upper floors & school is running on basement & ground + 01 upper floors. There is change of occupancy at basement & 1st floor has been newly added to the building. Hence is a case addition/alteration. During the inspection following shortcomings was observed:-

1. School is not accessible to fire engine due to encroachment.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(Atul Garg)
Director

Delhi Fire Service

07/06/23

Copy to:-

1. The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony, New Delhi-24.