



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No: F.6/DFS/MS/School/2023/WZ/ 174

Dated: 11/04/2023

To,

The Principal,  
New Sun Public School,  
K-1/196, Prem Nagar-II,  
Kirari, Delhi-110086.

Sub: - Regarding renewal of Fire Safety Certificate in r/o New Sun Public School, K-1/196, Prem Nagar-II, Kirari, Delhi-110086.

Sir,

This has reference to your letter no. nil received via outdoor diary no. 12240 dated 14.03.2023 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by officer concerned of this department on 29.03.2023 to see the compliance of the requisite fire safety measures. Smt. Vimla Shukla (Principal) was present at the time of inspection.

During the course of inspection it was observed that school building comprised of Ground Floor only. Your request of renewal of FSC is rejected as the following shortcoming was observed:-

1. Fire Extinguishers provided but not functional.

You are advised to rectify the above-mentioned shortcoming for taking further action as necessary for issuance of Fire Safety Certificate.

Yours Faithfully,

(Ajai Garg)  
Director

Delhi Fire Service

Copy to:-

1. Director of Education, Govt. OF NCT of Delhi, Old Secretariat, New Delhi.