



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/WZ/2023/ 701

Dated: 11 / 04 / 2023

To,

The Sahil Goel,
M/s. Shree Balaji Cosmetics,
Plot No.-54, Pvt No. - B-10,
Najafgarh Road, Industrial Area, Rama Road,
New Delhi-110015.

Sub : Regarding renewal of NOC from fire safety point of view in respect of M/s. Shree Balaji Cosmetics, Plot No.-54, Pvt No.- B-10, Najafgarh Road, Industrial Area, Rama Road, New Delhi-110015.

Sir,

Please refer to your Email dated 27/02/2023 on the subject cited above. In this connection, it is to inform you that the premises was inspected by officer concerned of this department on 20/03/2023 in the presence of Sh. Museh Kr. Goyal to see the functioning of fire safety equipments provided in the building.

During inspection, it has been observed that the premises is comprised of Basement + Ground + 02 Upper floors, was issued FSC vide letter No. F6/DFS/MS/2020/WZ/COS/224 dated 25/06/2020 for basement, ground plus 02 upper floors. Fire safety arrangements such as Fire Extinguishers, Hose reels, etc provided. However the following shortcomings were observed.

1. First Hose reels are provided but not functional.
2. Internal Hydrants are provided but not functional.
3. Terrace Fire pump of 450 lpm is provided but not on automode.
4. Over Head water storage tank capacity of 2500 ltrs is provided but uses as a domestic purpose.
5. Exit signages are found removed.

In view of above Shortcomings, the application for renewal of Fire safety Certificate is rejected. The occupancy of the Building/ premises in absence of requisite fire safety arrangements shall be at the risk and liabilities of the Owner/occupier. The licensing issuing authority/statutory authority is requested that premises should not be allowed to run till it provided all necessary fire arrangements.

Yours faithfully


(Atul Garg)
Director

Copy to: -

1. The Executive Engineer (Building) MCD, Karol Bagh Zone, Anand Parbat, New Delhi. (Email Id. - ceppwddelhim132@gmail.com)