

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F.6/DFS/MS/NDZ/ 2023/ 713

Dated 13/04/2023

To,

Sh. Khaliludin,
Authorized Signatory,
Ansal Bhawan, 16, K.G. Marg,
New Delhi.

Sub:- Regarding renewal of FSC in r/o Ansal Bhawan, 16, K.G. Marg, New Delhi.

Sir,

This has reference to your letter No. nil dated 14/03/2023 on the subject cited above. In this regard, it is to inform that the site was inspected by the officers concerned of this department on 06/04/2023 in the presence of yourself and the following shortcomings were observed:-

1. Fire check doors at some floors are not closing properly, required to be fixed properly.
2. Some Ventilation system in basement found nonfunctional.
3. Hose reel & hydrant are required to be extended at mezzanine floor also.
4. Smoke detector found non functional in some offices.

In view of above, you are requested to rectify above shortcomings at the earliest. Further, the occupancy of building /premises, in absence requisite fire & life safety arrangements, shall be at the risk and liability of the owner/occupier. The statutory/licensing authority may take suitable action as deemed fit.

Yours faithfully

(Ajit Singh)
DIRECTOR
Delhi Fire Service

Copy to :

The Chief Architect, NDMC, Platika Kendra, New Delhi.