

017



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001**

No. F6/DFS/MS/EH/2023/NDZ/ 182

Dated: 13/04/2023

To,  
Ms. Namita Sharama  
Dream Castle Restaurant (A Unit of Namita Enterprises)  
A-11, Jhilmil Industrial, G.T. Road,  
Delhi-110095

**Sub:-** Regarding Issuance of Fire Safety Certificate in r/o Dream Castle Restaurant (A Unit of Namita Enterprises) located A-11, Jhilmil Industrial, G.T. Road, Delhi-110095.

Sir,

With reference to your online MHA application No. 2023022802826 dated 28/02/2023 on the subject cited above. In this connection, it is to inform you that the officers concerned of this department have carried out the inspection of premises from fire safety point of view in presence of Mr. Gagan Poplin, Manager on dated 23/03/2023. The building comprised of basement, ground plus three upper floors. Proposed eating house is on ground floor. Following shortcomings were observed during the time of inspection.

1. Two doors of width 2.30 meter & 01 meter are provided against requirement of two doors 1.50 meter each.
2. First Aid Hose reel & Down-comer system is not provided.
3. MOEFA is not provided.
4. A fire pump having 450 lpm output of 40 meter head at terrace is not provided.
5. Over head water tank having 3,000 liters capacity is provided against the requirement of 20,000 liters.
6. Exits signage not provided.

In view of above, the application for issuance Fire Safety Certificate is rejected. The occupancy of building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

  
 (ATUL GARG)  
 DIRECTOR  
 DELHI FIRE SERVICE  
 o/c 2

Copy to:-  
The Joint Commissioner (Lic.)  
1<sup>st</sup> floor Police Station Defence Colony, New Delhi w.r.to MHA ID 2023022802826  
dated 28/02/2023