

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6/DFS/MS/2023/SZ/ 159

Dated 13/04/2023

To

The Joint Commissioner of Police (Lic Branch)  
1<sup>st</sup> Floor, Police Station  
Defence Colony, New Delhi.

Sub: - Regarding issuance of fire safety certificate in r/o M/s Hotel Ramhan situated at A-125, N.H- 8, Mahipalpur, New Delhi-110037.

Sir,

This has reference to your MHA Portal ID No. 2023011700688 Dated: 17.01.2023 on the subject cited above. In this connection this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 05.04.2023 to verify the fire safety arrangements as stipulated in NBC Part 4 and as well installed in the building. During the course of inspection, the following shortcoming observed were noticed:-

1. Fire check doors not provided at the building as per clause 7.31 of UBBL 2016.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

  
**ATUL GARG**  
**DIRECTOR**  
**DELHI FIRE SERVICE**

Copy to:

1. M/s Hotel Ramhan situated at A-125, N H- 8, Mahipalpur, New Delhi-110037.