

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

F6/DFS/MS//2023/ 716

Dated : 13/04/2023

To,

The Assistant Engineer (E), M-4511,
PWD DHC&ND/Central,
Delhi High Court, New Delhi.

Sub:- Request for Fire Safety Certificate (FSC) in r/o Multilevel Parking Zone, Delhi High Court New Delhi.

Sir,

This has reference to your letter no. 10(17)AE(E)/PWD/DHC&ND/C/M-4511/2022-23/463 dated 09.02.2023, on the subject cited above. In this connection, it is to inform that the site was visited by the officers concerned of this department on 28/03/2023 in the presence of **Sh. Y.P.S. Sharma (AE) & Sh. Deepak (JE)** CPWD and observed that the following shortcomings are observed:-

1. Smoke Management System found non functional and not integrated with alarm system.
2. Diesel Pump found non functional.
3. Sprinkler are required to be extended below the false ceiling.

In view of above, the Fire safety certificate cannot be issued. Therefore, you are requested to rectify the above shortcomings at the earliest for further consideration in the matter.

Yours faithfully


(Abul Garg)
DIRECTOR
Delhi Fire Service

Copy to:

1. The Honorable Registrar (Caretaking) Delhi High Court New Delhi.
2. The Executive Engineer (E), M-451, PWD DHC & ND /Central, New Delhi.