



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7/5  
आजादी का  
अमृत महोत्सव

No. F6 /DFS/MS/Industrial/SZ/2023 /724

Dated: 13/04/23

To,

The Indian Cornucopia Life style,  
Plot No F-24, Okhla Industrial Area Phase-I,  
New Delhi 110020.

**Sub: - Regarding renewal of Fire Safety Certificate in r/o Plot No F-24, Okhla Industrial Area Phase-I, New Delhi 110020.**

Sir,

This has reference to the your outdoor dairy no. 11982 dated 06.03.2023 on the subject cited above, it is informed that the said building was inspected by officer concerned of this department on 05.04.2023 in the presence of Mr. Ashok Rai (Manager) and it was observed that the building is comprised of **Basement + Ground + Mezzanine + 01 upper floors**. During the inspection following shortcomings was observed:

1. Fire check door (FCD) in common staircase found removed at Ground, Mezanine and 1<sup>st</sup> floor.

In view of above shortcomings, the application for renewal of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

  
(Aul Garg)  
Director

Delhi Fire Service

13/04/23

Copy to:-

1. The Executive Engineer (Building), South DMC, Jal Vihar, Lajpat Nagar, New Delhi-24.