



T. 11/04/2023
c/3

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/2023/NDZ/178

Dated: 11/04/2023

To

Mr. Rakesh Kumar,
Somras Bar & Restaurant (Bhavya Infoway Pvt. Ltd.)
Shop No. 10A, Ground Floor, Plot No. 01 A,
Star City Mall, Mayur Vihar, District Centre,
Delhi - 110091.

Sub.:- Inspection Report in r/o Somras Bar & Restaurant (Bhavya Infoway Pvt. Ltd.) Shop No. 10A, Ground Floor, Plot No. 01 A, Star City Mall, Mayur Vihar, District Centre, Delhi - 91.

Sir,

With reference to your MHA portal application No. 2022121021245 dated 23/02/2023 on the subject noted above. In this connection, it is to inform you that the said building premises was inspected by the officer concerned of this department on 27.03.2023 in the presence of Sh. Ravi Gupta.

During the course of inspection it was observed that the building premises is comprised of Basement, Ground & Two upper floors **(Restaurant is running on Ground Floor only)**

Following shortcomings were observed during the time of inspection:-

1. Fire Check Doors not provided in Kitchen.
2. MOEFA (Manual Operating Electric Fire Alarm) provided but nonfunctional.
3. Exit signage not provided.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building / premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner / occupier.

Yours faithfully,


(ATTL CARG)
DIRECTOR
DELHI FIRE SERVICE
o/c DPH

Copy to :-

1. Dy. Commissioner of Police (Lic.), 1st Floor, Police Station Defence Colony, New Delhi-110025.