

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001**

No. F6/DFS/MS//2023/SZ/ 736

Dated: 17/04/23

To,

The Asstt. Engineer (Elect.)/WZ,
Old Zonal Office Building, Vishal Enclave,
Rajouri Garden, New Delhi-110027.

Sub: - Regarding renewal of "Fire Safety Certificate" from fire safety point of view in r/o M/s Conventional Underground Car Parking, J-8, Rajouri Garden, New Delhi-110027.

Sir,

Please refer to your letter No. AEE/2022-23/MCD/WZ/5 dated 06/03/2023 on the subject cited above. In this connection this is to inform you that officers concerned of this department inspected the building to verify the fire safety arrangements in accordance with the rules. At the time of inspection Sh. Vinay Kumar Sharma (AE MCD) was present and it was observed that the building is comprised of three tier basements and have following shortcomings:-

1. Fire damper system provided but not functional.
2. Smoke management system provided but not functional.
3. First aid hose reels provided but not functional.
4. MOEFA provided but not functional.
5. Public addressing system provided but not functional.
6. Automatic Sprinkler System provided but not functional.
7. Internal hydrant & yard hydrant provided but not functional.
8. Fire pumps provided but not functional.
9. Pressurization system of lift shaft & lift lobby provided but not functional.

In view of above shortcomings, the application for renewal of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk & liability of the owner/occupier. The Licensing Authority/Statutory Authority may be take suitable necessary action as deemed fit.

Yours faithfully

(Atul Garg)

Director

Delhi Fire Service

9/4