

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F.6/DFS/MS/2023/ 723

Dated: 13/04/2023

To

The Executive Engineer (E),
Vigyan Bhawan Electric Division, CPWD,
Vigyan Bhawan Annexe, New Delhi.

Sub:- Regarding issuance of fire safety certificate(FSC) in r/o Vigyan Bhawan, New Delhi.

Sir,

This has a reference to your letter no. 20(35)VBED/2022-23/623 dated 01.03.2023 on the subject cited above, it is to inform you that the site was inspected by the officers concerned of this department on 06/04/2023 in the presence of Sh. Janendra, JE, CPWD and following shortcomings were observed:-

1. Smoke management system is not provided in basement, main hall and atrium near escalator.
2. Hose reels/hydrants are not covering entire area at ground and upper floor, required to be extended in left out area.
3. Detectors found nonfunctional in some area.
4. Lift Signages "not to use lift in case of fire" are not provided.
5. Seating arrangement in main hall at ground floor is not provided as per cinematograph act-1952 / NBC part-4.

In view of above shortcomings, request for issuance of fire safety certificate is rejected. There for you are requested to rectify the above shortcomings at the earliest. Further, the occupancy of building /premises, in absence requisite fire & life safety arrangements, shall be at the risk and liability of the owner/occupier. The statutory/licensing authority may take suitable action as deemed fit.

Yours faithfully

(Abul Garg)
DIRECTOR
Delhi Fire Service

Copy to:-

1. The Chief Architect, NDMC, Palika Kendra, New Delhi.