

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI - 110001**

NO. F6/DFS/MS/CGHS/SZ/2023/ 775

DATED: 18/04/2023

To,

The President,
Apoorva CGHS Ltd.
Plot No. 14, Sector-05, Dwarka,
Phase - 1, New Delhi - 110075.

Subject: - Renewal of Fire safety Certificate from fire safety & means of escape point of view in r/o Apoorva CGHS Ltd. Located at Plot No. 14, Sector-05, Dwarka, Phase - 1, New Delhi - 110075.

Sir,

Please refer to your letter No. Nil dated 21/03/2023 on the subject cited above. In this connection it is to inform you that the above said premises was re-inspected by the officer concerned of this department on 05/04/2023 in the presence of Sh. Sanjeev Kumar Sultana (President) for fire safety point of view.

During the course of inspection followings shortcoming have been observed:-

1. Trimming of the trees must be done to provide clear passage around the building to fire vehicles in case of any emergency.
2. Only one ABC type fire extinguisher is found provided at each floor against required two fire extinguishers.
3. Hoses and Branches found missing at some floors/ places.

You are requested to comply the abovementioned shortcomings under intimation to this department.

In view of the above shortcomings Fire Safety Certificate cannot be considered at this stage.

Yours faithfully,

(Atul Garg)
(Director)

Delhi Fire Service

Copy to:-

1. The Joint Director, DDA, Vikas Sadan, INA, New Delhi.

FD
18/4/23