



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No.F6/DFS/MS/2023/EH/ 101  
To

Dated 18/04/2023

Ministry of Home Affair  
Portal.

**Sub:** - Regarding issuance of fire safety certificate in r/o M/s Barbeque Nation (A Unit of Ms Barbeque Nation Hospitality Ltd.) located at 3<sup>rd</sup> Floors, B-2, Gujrawala Town, Part-1, Delhi-110009.

Sir,

This has reference to your online I.D. No. 2023030703263 dated 09.03.2023 on the subject cited above. In this connection this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 28.03.2023 in the presence of Mr. Bijender (Manager) to verify the fire safety arrangements as stipulated in NBC Part 4 and as well installed in the building. During the course of inspection it has observed that the building/premise is comprised of basement, ground & 03 upper floors but (Restaurant is proposed at 3<sup>rd</sup> floor only). Your request for FSC is rejected under Rule 35 (3) due to following shortcomings.

- 1 Smoke ventilation system is not provided at third floor.
- 2 Electrical Driven Fire Pump capacity of 2280lpm., Diesel Engine Pump capacity of 2280lpm and Jockey Pump capacity of 180lpm not provided.
- 3 Terrace level fire water tank capacity of 1,00,000ltr provided interconnected and found badly leakage condition. Needs to be repair.

Keeping in view of above Fire Safety Certificate cannot be considered at this stage. You may apply again on form 'I' as stipulated in sub rule (2) 35 of rules, DFS Rules 2010 after compliance of the shortcoming mention above. The link for forms is as under available on <http://delhi.gov.in/wps/wcm/connect/doit fire/FIRE/Home/Forms>.

Yours faithfully

(Atul Garg)  
Director

Ph: 011-23414000