

c/6

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE

NEW DELHI

No. F6/DFS/MS/SZ/2023/ 190

Dated: 18/04/2023

To,
The Addl. Commissioner of Police (Lic),
1st Floor, Licensing Unit, Police Station,
Defence Colony, New Delhi.

Subject: Issuance of NOC from fire safety point of view in r/o M/s Big Yellow Door (A unit of Shanjan Hospitality) Located at Plot No. 229, 2nd floor Sector – 9, Dwarka, New Delhi – 110075.

Sir,
Please refer to online application No. 2023031803858, dated 20-03-2023 on the subject mentioned above. In this connection it is to inform you that the premise was inspected by the team of officers concerned from this department on 28/03/2023 in the presence of Sh. Rihan (Manager) for fire safety point of view.

During the course of inspection the following shortcomings are observed.

1. Two stairs of 1.5m clear width are found not provided.
2. Two Exits of 1.5 M width found not provided.
3. Smoke exhaust system found not provided in basement.
4. Automatic fire detection system and alarming system found not provided
5. MOEFA found not provided.
6. Main Pump & Standby pump of 2280 lpm at ground level found not provided.
7. Jockey pump of 180 lpm found not provided.
8. Terrace pump of 450LPM found not provided.
9. Hydrant & Hose Reels are found not provided.
10. Terrace fire water tank of 10,000 ltrs found not provided.
11. Underground fire water tank of capacity 1,00,000 ltrs found not provided.
12. Exit signage found not provided.
13. Restaurant activities are also noticed at 3rd floor.

Applicant may be requested to comply the shortcomings under intimation with this department for further consideration in the matter

In view of the above Fire Safety Certificate from fire safety point of view cannot be considered at this stage


(Arul Garg)
Director
Delhi Fire Service

Copy to: -

1. The Manager, M/s Big Yellow Door (A unit of Shanjan Hospitality) Located at Plot No. 229, 2nd floor Sector – 9, Dwarka, New Delhi – 110075.
2. Deputy Health Officer, Health Department, SDMC, Dhansa stand, Najafgarh, New Delhi – 110043.

1/3/23