



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2023/WZ/ 140

Dated: 27/03/2023

To,

The Principal,
Govt. Sarvodaya Kanya Vidyalaya,
Bharat Nagar, Delhi-110052.

Subj:- Regarding renewal of Fire Safety Certificate in respect of Govt. Sarvodaya Kanya Vidyalaya, located at Bharat Nagar, Delhi-110052.

Sir,

This has reference to your letter no SKV/BV/2023/370 dated 01.02.2023 on the subject cited above. In this connection, it is to inform you that the said school building has been inspected by the officer concerned of this department on 15.03.2023 in the presence of Sh. Sanjeev Kumar (Estate Manager). During inspection, it has been observed that the school building is comprised of Ground floor only served with 04 staircases. However the following shortcoming has been observed:-

1. ABC types of fire extinguishers found non-functional.

In view of the above shortcomings, Fire safety Certificate cannot be renewed at this stage & rejected. You are advised to rectify the above mentioned shortcomings under intimation to this department for taking further necessary action.

Yours faithfully,

(A. J. Singh)
Director
Delhi Fire Service

Copy to:-

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi 110054