

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**  
**NEW DELHI- 110001**

No. F.6/DFS/MS/GH/2023/SZ/ 169  
To

Dated: 18.04.2023

The Joint Commissioner of Police, Lic/Branch,  
1<sup>st</sup> Floor, P.S Defence Colony  
New Delhi 110049.

Sub: Regarding Issuance of NOC in r/o M/s Hotel Stanley located at A-192, NH-8, Road No 4,  
Mahipalpur Extn. New Delhi-110037.

Sir,

This has reference with MHA Portal ID 2023030403153 dated 04/03/2023 on the subject cited above. In this connection, the premises have been inspected by officer concerned of this department on 05.04.2023. During the inspection, it was observed that building is comprised of Basement Ground plus four upper floors but the Guest House is running Ground + Three Upper Floors. The shortcomings observed are as below:

1. There is a 4<sup>th</sup> floor of the building. As per the notification dated 27/05/2019 fire NOC for guest House will not be issued to those building, which have more than four floors (excluding basement & stilt floor)

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL KARG)  
DIRECTOR

DELHI FIRE SERVICE

q/w