



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7/5
आजादी का
अमृत महोत्सव

No.F6/DFS/MS/GH/SZ/2023/ 163

Dated: 18/04/2023

c/96

To

The Joint Commissioner of Police (Licensing),
1st Floor, Police Station,
Defence Colony, New Delhi.

Sub:- Regarding renewal of Fire Safety Certificate in r/o **M/s Karan Palace Guest House, 185/K/3, Sarai Jullena, New Delhi-25.**

Sir,

With reference to the online application no. 2023032204027 dated 23.03.2023 on the subject cited above, it is informed that the building was inspected by Assistant Divisional Officer (M. Road) from this department on 05.04.2023 in the presence of Sh. Baburam Sharma (Manager) and it was observed that the building is comprised of Basement + Ground + 03 upper floors. During the inspection following shortcomings were observed:-

1. Fire Check Door (FSD) not provided as required in the Gazette Notification dated 27.05.2019 (Clause 7.31 UBBL 2026).
2. CO Detection system found non functional.
3. Hose reel found non functional.
4. Manual Operated Electrical Fire Alarm (MOEFA) system found non functional.
5. Automatic sprinkler system found non functional in basement.
6. Fire pump found non functional.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)

Director

Delhi Fire Service

9/6/24