

018

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/GH/NDZ/ 164

Dated: 18.04.2023

To,

The Manager,
M/S Royal Rosette,
5225 Dal Mandi, Shora Kothi,
New Delhi.

Sub: Issuance of FSC (Fire Safety Certificate) in r/o M/S Royal Rosette, 5225 Dal Mandi, Shora Kothi, New Delhi. ID No.2023031003370 dated 10.03.23.

Sir,

This has reference to on line ID No.2023031003370 dated 10.03.23, on the subject cited above. In this regard, it is to inform you that the site was inspected by the officers concerned of this department on 05/04/2023 in the presence of Sh. Sashi Bhushan (Care Taker) and following shortcomings were observed: -

1. Width of corridor provided 1.40 meter against the requirement of 1.8 meter.
2. Building Plan as uploaded does not match with existing profile of the guest house.
3. The proof of width of ROW of PSS area on which guest house is situated is required to be submitted.

Hence, Fire Safety Certificate (FSC) cannot be issued at this stage due to above shortcomings. Therefore, you are requested to rectify the above shortcomings and re-submit for further consideration in the matter.

Yours faithfully,

(Atul Singh)
DIRECTOR
01123414000

Copy to:-

1. The Addl. Commissioner of Police (Lic.) First floor, PS Defence Colony New Delhi.