



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/Banquet/2023/NDZ/ 793

Dated: 21/04/2023

To

Authorized Signatory,
Shubham Hall Shree Laxmi Narayan Sewa Ashram
Trust (Regd.) Mandawali Fazalpur (Near Balco Society Mkt.) Delhi-110092.

Subject:- Regarding Renewal of "Fire Safety Certificate" from fire safety point of view in r/o Shubham Hall Shree Laxmi Narayan Sewa Ashram Trust (Regd.) Mandawali Fazalpur (Near Balco Society Mkt.) Delhi-110092.

Sir,

This has a reference to your MHA portal application No. 2023032904486 Dated 31/03/2023, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 17/04/2023 in the presence of Mr. Raja Bhaiya Kushwaha (Service) and observed that building comprised of Basement, Ground, First & Second Floor (Banquet Hall is running on Ground & 1st Floor only).

Following shortcomings were observed during time of inspection :

1. Fire Check door found removed as indicated in plan.
2. Hose Reel Hose, Internal Hydrants & Automatic Sprinkler System provided but found nonfunctional.
3. All Fire pumps v.i.z ground & terrace fire pumps found non functional.
4. Stand by Diesel pump of 900 LPM capacity found removed.
5. Lift signage & Fire man grounding switch also found removed.
6. Over head tank of 5000ltr capacity is provided against requirement of 10,000 ltr capacity.
7. Kitchen should be removed immediately which is operating upon underground water static tank & near ground fire pumps.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building / premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner / occupier. The Licensing Authority / Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

1. Joint Commissioner of Police (Lic.) P. S. : Defence Colony, New Delhi-110024 w.r.t. MHA portal ID-2023032904486 Dated 31/03/2023.
2. The Dy. Health Officer, MCD, Health Department, 419, Patparganj Industrial Area, Delhi-110092 w.r.t.MHA portal ID No. 2023032904486 Dated 31/03/2023.