



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110 001**

75
आज़ादी का
अमृत महोत्सव

No. F. 6. / DFS / MS / BP / 2023/ 88

Dated: 20/04/2023

To,

The Executive Engineer (Bldg.) HQ-I,
Municipal Corporation of Delhi,
8th Floor, E-1 Wing, Dr. S.P.M. Civic Centre,
Minto Road, New Delhi-110002.

Subject: Online building plans in r/o the proposed construction of warehouse at property No. 33/9, MIN 1- 2, village – Paprawat, Kapashera, New Delhi.

Sir,

Please refer your online ID No. 10113205 dated 13-04-2023 on the subject cited above. In this connection it is to inform you that the building plans have been scrutinized from fire/life safety point of view and observed following short comings:

1. Information, provided in CAF is not as per UBBL-2016/NBC, Part-4, 2016.
2. Compartmentation is not marked on the plan.
3. Smoke venting scheme/plans are not provided.
4. Fire fighting arrangements such yard hydrants are not marked on the plans.

Therefore, the proposal is rejected with request to rectify above shortcomings and re-submit plans for further consideration in the matter.

Yours faithfully,

(ATUL GARG)
DIRECTOR

Ph.: 011-23414000