

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6/DFS/MS/EH/2023/196

Dated 19/04/2023

To

The Dy. Health Officer, (Najafgarh Zone)
Public Health Officer,
Dhasa Bus Stand, Najafgarh,
New Delhi 110043

Sub: - Regarding issuance of fire safety certificate in r/o M/s Basil Delhi Apartments Private Limited, (A Unit of Delhi Apartment Private Limited) at Ground Floor, Kh. No 33.1.10.2, NH-8, Village Samalka New Delhi 110037

Sir,

This has reference to your MHA Portal ID No. 2022120621096 dated 01/06/2023 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 05.04.2023 to verify the fire safety measures installed in the building and observed that restaurant running at ground floor only. During inspection, following points were observed:

- 1 First aid Hose reel not provided in side restaurant.
- 2 Internal Hydrant not provided in side restaurant.
- 3 Terrace level Fire Pump capacity of 450 LPM provided but found not functional.
- 4 Dedicated overhead tank capacity 20,000 ltrs not provided.
- 5 Exit Signage not provided.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:-

1. The Joint Commissioner of Police, Lic/Branch, 1st Floor, P S Defence Colony, New Delhi -110049. For taking necessary action on the matter