

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/School/2023/SZ/149
To

Dated 29.10.2023

The Principal,
NGF Junior School,
T-21, Khirki Extn. Malviya Nagar,
New Delhi 110017

Sub: Regarding issuance of FSC in r/o NGF Junior School, T-21, Khirki Extn. Malviya Nagar, New Delhi 110017

Sir,

This has reference to your Email dated 13-03-2022 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 18.03.2023 in the presence of Mr. Ashish Kumar to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. First aid hose reel provided but found non functional.
2. Automatic sprinkler system provided but found non functional.
3. Terrace level Fire Pump capacity of 450 LPM provided against the required capacity of 900 LPM.
4. The fire fighting tank capacity 5000 ltrs provided against the required capacity of 15,000 ltrs.
5. Exit signage found removed in some places.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to:-

1. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054