

26

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE

NEW DELHI

No. F6/DFS/MS/SZ/2023/EH/200

Dated: 24/04/2023

To,

The Addl. Commissioner of Police (Lic),
1st Floor, Licensing Unit, Police Station,
Defence Colony, New Delhi.

Subject: Issuance of NOC from fire safety point of view in r/o Pind Balluchi (A unit of Triom Hospitality) Located at Plot No. 06, 2nd floor, MLU Pankaj Arcade, Pocket 14, Dwarka Sector – 11 New Delhi.

Sir,

Please refer to online application No. 2023040104850, dated 10-04-2023 on the subject mentioned above. In this connection it is to inform you that the premise was inspected by the team of officers concerned from this department on 13/04/2023 in the presence of Sh. Surya Prakash (General Manager) for fire safety point of view.

During the course of inspection the following shortcomings are observed.

1. Two stairs of 1.5m clear width are found not provided.
2. Two Exits of 1.5 M width found not provided.
3. Automatic fire detection system and alarming system found not provided
4. MOEFA found not provided.
5. Main Pump & Standby pump of 2280 lpm at ground level found not provided.
6. Jockey pump of 180 lpm found not provided.
7. Terrace pump of 450 LPM found not provided.
8. Hydrant & Hose Reels are found not provided.
9. Terrace fire water tank of 10,000 ltrs found not provided.
10. Underground fire water tank of capacity 1,00,000 ltrs found not provided.
11. Exit signage found not provided.

Applicant may be requested to comply the shortcomings under intimation with this department for further consideration in the matter

In view of the above Fire Safety Certificate from fire safety point of view cannot be considered at this stage


(Atul Garg)
Director
Delhi Fire Service
ok

Copy to: -

1. The Manager, Pind Balluchi (A unit of Triom Hospitality) Located at Plot No. 06, 2nd floor, MLU Pankaj Arcade, Pocket 14, Dwarka Sector – 11.
2. Deputy Health Officer, Health Department, SDMC, Dhansa stand, Najafgarh, New Delhi – 110043.