

C-93

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS : DELHI FIRE SERVICE, NEW DELHI - 110001**

No. F6/DFS/MS/GH/NDZ/2023/173

Dated: 24/04/2023

To  
The Joint Commissioner of Police (Licensing),  
1<sup>st</sup> Floor, Police Station Defence Colony,  
New Delhi.

**Sub:** Regarding renewal of Fire Safety Certificate in respect of **M/s Rang Mahal Guest House** situated at **3731, Netaji Subash Marg, Darya Ganj, Delhi - 06.**

Sir,

This is in reference to online application I.D. no.2023032404187 dated 24.03.2023 on the subject cited above. It is to inform you that the guest house was inspected by the officer concerned from this department on 04.04.2023 in the presence Mr. Sudhir Jain (Owner's) and it was observed that the building is comprised of ground + 01 upper floor, guest house is running at ground floor only. During inspection, following shortcomings were observed:

1. Fire check door not provided which are required as per gazette notification dated 27.05.2019.
2. Fire extinguishers not adequately provided.
3. CO detectors with panel and alarm system not provided which are required as per gazette notification dated 27.05.2019.
4. Fire pump not in auto start mode.
5. Upload the elevation plan of the building wherein height of the each floor mentioned and duly signed by architect & owner/ occupier.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

The applicant is requested to rectify the shortcomings at the earliest for further action.

Yours faithfully,

  
(Atul Garg)  
Director  
Delhi Fire Service  
Tel: 011-23414000  
19/4

**Copy to:-**

The Licensee,  
M/s Rang Mahal Guest House, 3731, Netaji Subash Marg, Darya Ganj, Delhi - 06.