

c-6

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/GH/NDZ/172

Dated: 24.04.2023

To,

The Manager,
M/S UPTOWN, Guest House,
Plot No-7, Block 80 A, Krishna Market,
Pahar Ganj, New Delhi.

Sub: Regarding issuance of FSC (Fire Safety Certificate) in r/o M/S UPTOWN, Guest House,
Plot No-7, Block 80 A, Krishna Market, Pahar Ganj, New Delhi.


Sir,

This has reference to your online id no 2023031703829 dated 28.03.2023, on the subject cited above. In this regard, it is to inform you that the site was visited by the officers concerned of this department on dated **11.04.23** in presence of **Manager** and following shortcomings are observed.

1. FCD on the staircases are not installed as per gazette notification 27.05.2019.
2. Smoke management system in basement is not provided.
3. One pump of 450 LPM is provided on the terrace against the requirements of 02 pump.

Hence, Fire Safety Certificate (FSC) cannot be issued at this stage. Therefore, you are requested to submit the complete compliance of the shortcomings for further consideration in the matter.

Yours faithfully,


(Atul Garg)
DIRECTOR

Delhi Fire Service



Copy to :-

1. The Addl. Commissioner of Police (Lic.) First floor, PS Defense Colony, New Delhi.