



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7/6
आजादी का
अमृत महोत्सव

e-15

No.F6/DFS/MS/School/SZ/2023/189

Dated: 17/04/23

To

The Principal,
U.P. Project School (Tiny Tots Education Society Redg.)
Canal Colony, New Delhi-25.

Sub:- Regarding renewal of Fire Safety Certificate in respect of U.P. Project School (Tiny Tots Education Society Redg.) located at Canal Colony, New Delhi-25.

Sir,

With reference to outdoor diary no.12662 dated 28.03.2023 on the subject cited above, it is informed that the school building was inspected by Assistant Divisional Officer (M. Road) from this department on 06.04.2023 in the presence of Principal and it was observed that the building which was earlier comprised of ground floor only is now comprised of ground + 01 upper floors & school is running on ground + 01 upper floor. 1st floor has been newly added to the building. Hence is a case addition/alteration. During the inspection following shortcomings were observed:-

1. One more staircase is required having width not less than 0.75 meters.
2. Fire extinguishers found non functional.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)
Director

Delhi Fire Service

Copy to:-

1. The Dy. Director of Education, GNCT of New Delhi DISST, South Block-C, Defence Colony, New Delhi-24.