

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No. F6/DFS/MS/NDZ/2023/ 887

Dated: 03/05/2023

To,

The Assistant Engineer,  
PWD, Health maintenance Electric Sub Division (Central),  
GIPMER, New Delhi.

**Sub: Regarding renewal of "A" block GIPMER (GB Pant Hospital) New Delhi.**

Sir,

This has reference to your letter no. 10 (07) AE(E)/PWD/HC-3/2022-23/74 dated 27.03.2023 on the subject cited above. In this regard, it is to inform you that the site was visited by officers of Delhi Fire service on dated 21/04/2023 in the presence of Sh. Manish Kumar (JE) & Sh. N.L. Gupta AE (E) During the inspection following shortcomings were observed

1. 02 staircases found blocked by dumping of waste materials.
2. Corridor found encroached which create an obstacle to free movement of Occupants/patients.
3. Detection system found nonfunctional.
4. Smoke management system is not provided at upper floors.
5. Hose boxes found removed at some places.
6. Lift signages are not provided.

Hence, Fire Safety Certificate cannot be considered at this stage. Therefore, it is requested to rectify the above shortcomings for further consideration in the matter.

Yours faithfully

(Atul Garg)  
DIRECTOR

Delhi Fire Service

Copy to:-

1. The Medical Director, GIPMER (G.B.Pant hospital) New Delhi.
2. CMO, Nodal officer, PWD, GIPMER (G.B.Pant hospital) New Delhi.