

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F.6/DFS/MS/2023/99

Dated:- 03/05/2023

To

Sh. Ashok Kumar,
Chief Architect,
CPWD, Room No 217-218, A Wing,
Nirwan Bhawan, New Delhi.

Sub:- Regarding issuance of fire safety certificate (FSC) in r/o New Parliament building, 118 NA Raisina Road, Central Vista, New Delhi.

Sir,

This has reference to your online application no. REGION DELHISUB REGION20201214/2234 DATED 11.04.2023 on the subject cited above, it is to inform that the site was inspected by the officers concerned of this department on 24/04/2023 in the presence of Sh. Vishesh Swamival, EE (E), Sh. Chiranjeev, AE (C) & Sh. Rajib Mandal, Project Director and the following shortcomings were observed:-

1. 06 meter wide road all around the building is not completed as per UBBL-2016.
2. Fire check doors on the staircase are not provided in basement.
3. Width of staircase doors and room doors are not provided as per UBBL-2016.
4. Staircase serving to basement are not segregated as per UBBL-2016
5. Compartmentation is not done.
6. Shafts /Openings are not sealed horizontally & vertically.
7. Smoke management system works is under progress at some places.
8. Sprinklers & detectors work are under progress at some places /offices.
9. Hose boxes are not provided at yard hydrants.
10. Fire extinguishers of different type such as CO2, ABC & Clean agents are not provided.
11. Lift lobby pressurization is not completed.
12. Exit signages / lift signages are not provided.
13. Width of aisles in Lok Sabha is not provided as per cinmograph act.
14. Electric panels are not protected with gas tube flooding system.
15. Fireman switch at lift is not placed properly.
16. Hose reel & Hydrant required to be extended at terrace level
17. Building floor/evacuation plan is required to be provided at Fire control room.

In view of above, FSC cannot be issued at this stage. Therefore, it is requested to rectify the above shortcomings at the earliest and re-submit for further consideration in the matter.

Yours faithfully


(Atul Garg)
DIRECTOR
Delhi Fire Service