

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No.F.6/DFS/MS/2023/ 895

Dated:- 04.../05/2023

To,

Sh. M.R. Mishra,
Chief Administrative Officer,
The Press Trust of India Limited,
P.T.I. Building, 4, Parliament Street, New Delhi.

Sub:- Inspection report in r/o Press Trust of India Limited, P.T.I. Building, 4, Parliament street,
New Delhi.

Sir,

This has reference to your letter No.CAO-131/23 dated 18/04/2023 on the subject cited above. In this regard, it is to inform you that the site was re-inspected by the officers concerned of this department on 27/04/2023 in the presence of Sh. M.R. Mishra, Chief Administrative officer. The following shortcomings were observed:-

1. Detectors are required to be provided at some offices and third floor also.
2. Openings /shafts are not sealed properly.
3. Exit signages found inadequate.

In view of above, application for renewal of FSC is rejected. Therefore, you are requested to rectify the above shortcomings at the earliest under intimation to this department.

Yours faithfully,


(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to:-
The Chairman, NDMC, Palika Kendra, New Delhi,.