

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No: F.6/DFS/MS/School/2023/WZ/208

Dated: 26-04-2023

To,

The Principal,
Rana Public School,
Sahibabad Daulatpur,
Delhi-110042.

Sub: - Regarding renewal of Fire Safety Certificate in r/o Rana Public School, Sahibabad Daulatpur, Delhi-110042.

Sir,

This has reference to your letter no. RPS/GA/01/2003 received via outdoor diary no. 12633 dated 27.03.2023 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by officer concerned of this department on 06.04.2023 to see the compliance of the requisite fire safety measures. Sh. R.S. Rana (Manager) was present at the time of inspection.

During the course of inspection it was observed that school building comprised of Ground and First Floor. Your request of renewal of FSC is rejected as the following shortcomings were observed:-

- 1. First Aid Hose Reel provided but not functional.
- 2. Terrace level pump provided but not functional.

You are advised to rectify the above-mentioned shortcoming for taking further action as necessary for issuance of Fire Safety Certificate.

Yours Faithfully,


 (Ashu Gupta)
 Director
 Delhi Fire Service


Copy to:-

- 1. Director of Education, Govt. Of NCT of Delhi, Old Secretariat, New Delhi.