

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI- 110001

No. F6/DFS/MS/Educational/2023/SZ/ 18

Dated: 04/05/2023

To,

Sh. Ajeet Singh Choudhary (Secretary),  
Surajmal Memorial Education Society (Regd.),  
C-4, Janak Puri, New Delhi-110058.

**Sub:** - Regarding issue of "Fire Safety Certificate" from fire safety point of view in r/o Surajmal Memorial Education Society (Regd.), C-4, Janak Puri, New Delhi-110058.

Sir,

Please refer to online ID No. 10114800 dated 26/04/2023 on the subject cited above. In this connection this is to inform you that officers concerned of this department inspected the building to verify the fire safety arrangements in accordance with the rules. At the time of inspection Sh. Ajeet Singh Choudhary (Secretary) was present and it was observed that the building is comprised of Stilt plus seven upper floors and have following shortcomings:-

1. Electrical shaft not sealed.
2. Smoke management system provided but not functional.
3. Fire extinguishers are not provided.
4. First aid hose reels provided but not functional.
5. PA System not provided.
6. Internal hydrant & Yard hydrant provided but not functional.
7. Fire pumps are provided but not functional.
8. Exit signage's are not sufficient.
9. Design of Fire Tower is not provided as per NBC 2016 Part-IV.
10. Pressurization system for fire tower and lift lobby not provided.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk & liability of the owner/occupier. The Licensing Authority/Statutory Authority may be take suitable necessary action as deemed fit.

Yours faithfully

(Aul Garg)  
Director  
Delhi Fire Service

2023

Copy to:-

1. Executive Engineer (MCD), South West Zone, Rajouri Garden, New Delhi.