



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/2023/NDZ/44/187

Dated: 04/05/2023

To

Authorized Signatory,
Amar Devi Family Welfare Trust
House No 44, Hasanpur, Delhi- 110096.

Subject:- Regarding issued of "Fire Safety Certificate" from fire safety point of view in r/o
Amar Devi Family Welfare Trust, House No 44, Hasanpur, Delhi- 110096.

Sir,

This has a reference to your MHA portal application No. 2023032003969 Dated 22/03/2023, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 17/04/2023 in the presence of Sh. Mohit and observed that building comprised of Basement, Ground & Three Upper Floors but guest house is running at 2nd & 3rd floors only.

Following shortcoming was observed during time of inspection :

1. Fire Check Door not provided.

Keeping in view of above shortcomings, the application for issuance of Fire Safety Certificate cannot be considered at this stage. You are requested to rectified above mentioned shortcoming under intimation to this department for taking necessary action in this matter.

Yours faithfully,

(ATUL GARG)

DIRECTOR
DELHI FIRE SERVICE

Copy to :-

1. Dy. Commissioner of Police (Lic.), 1st Floor, PS Defence Colony, New Delhi-110024 w.r.t. MHA portal application No. 2023032003969 Dated 22/03/2023.