

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELIH HEADQUARTERS, DELIH FIRE SERVICE, NEW DELIH-110001

No. F6/DFS/MS/EH/WZ/2023/235

Dated: 08 /05 /2023

Yours faithfully

To

The Joint Commissioner of Police, Licensing Unit, 1st floor, Police Station, Defence Colony, New Delhi, addlep.lic-dl@nic.in

Subject: Regarding issuance of NOC from fire safety point of view in respect of M/s.

Connaught Plaza Restaurants Pvt. Ltd. McDonalds Family Restaurant located at Shop No- 03, Ground Floor, 1- District centre, Rajouri Garden, New Delhi-110027.

Sir.

Please refer to your online application no. 2023032103990 dated 04/04/2023 on the subject cited above. In this connection, it is to inform you that the premises was inspected by officer concerned of this department on 26/04/2023 in the presence of Mr. Anurag Srivastava to see the functioning of fire safety equipments provided in the building.

During inspection, it has been observed that the above said restaurant is running at Ground Floor in Vishal Cinema in a Building comprised of 02 Basement, Ground plus 04 Upper floors. Fire safety arrangements such as Fire Extinguishers, Smoke Management system, First Aid Hose Reels etc provided. However the following shortcomings were observed.

 Width of door size is provided 1.13mtr & 1 x 2mtr against requirement of 2 x 1.5mtr. 01 door of width 2mtr is also provided running through kitchen which is not acceptable.

In view of above Shortcomings, the application for issuance of Lire safety Certificate is rejected. The occupancy of the Building/ premises in absence of requisites fire safety Arrangements Shall be at the risk and liabilities of the Owner/occupier. The licensing issuing authority/statutory authority is requested that premises should not be allowed to run till it provided all necessary fire arrangements.

Copy to -

 The Owner/Occupier, Ms Connaught Plaza Restaurants Pvt. Ltd. McDonalds Family Restaurant located at Shop No- 03, Ground Floor, 1- District centre, Rajouri Garden, New Delhi-110027