



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आज़ादी का
अमृत महोत्सव

No. F6/DFS/MS/SZ/2023/ 17

Dated: 03/05/2023

To

Mr. S.S. Akhtar (Registrar),
Jamia Hamdard Nano Biotechnology Centre of Advance Research,
Hamdard (Hamdard University),
Hamdard Nagar, New Delhi-62.

Sub: - Regarding issuance of Fire Safety Certificate in respect of M/s **Jamia Hamdard Nano Biotechnology Centre of Advance Research located at Hamdard (Hamdard University), Hamdard Nagar, New Delhi-62.**

Sir,

This has reference to your letter no. JH/E&M/Fire Safety/Nano/2023/01 dated 10.03.2023 on the subject cited above, it is informed that the said building was inspected by a team of officers from this department on 19.04.2023 in the presence of Mr. Muzaffer Hasan, Sr. Civil Engineer & Mr. Salim, AE Civil and it was noticed that the building is comprised of Basement, Ground + 03 upper floors having following occupancies.

1. Basement – Offices
2. Ground floor – Class rooms
3. 1st to 3rd floors – Labs & related offices

The building is chiefly having business occupancy and the total height of the building as per records is below 15 meters which is not covered under Rule 27 of Delhi Fire Service Rule 2010. Hence fire safety clearance from this department is not required.

However, building management is requested to maintain the fire protection measures as per NBC part IV, 2016 (table 7) in the larger interest of public safety.

Yours faithfully,

(Aul Garg)
Director

Delhi Fire Service

o/c A.G.
03/05/23

Copy to-

1. The Commissioner: South Delhi Municipal Corporation, Civic Centre, Minto Road, New Delhi-110002.