



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

c-24  
7  
08/05/23

No. F6/DFS/MS/2023/WZ/230

Dated:- 08/05/2023

To,

The Joint Commissioner of Police,  
Licensing unit, 1<sup>st</sup> Floor,  
Police Station, Defence Colony, New Delhi.

**Subject:- Inspection report for issuance of Fire Safety Certificate in r/o M/s. Miraco Ventures Private Limited, located at G-4, First Floor, Pushkar Enclave, Paschim Vihar, New Delhi-110063.**

Sir,

With reference to the online application received through MHA portal vide ID-2023040405216 dated 06.04.2023 on the subject cited above. In this connection it is to inform you that the said restaurant was inspected by the officers concerned of this department on 29.04.2023 in the presence of Sh. Rohit Bhardwaj (Manager), to check the shortcomings issued by this department vide letter no. F.6/DFS/MS/EH/WZ/2022/726 dated 14.12.2022

During the course of inspection, it has been observed that the Management has rectified some of the shortcomings, the status is under:-

S. no.	Shortcomings	Status
1.	One additional Staircase having width 1.5 m is required	Provided but not meeting requirement
2.	Fire pump found provided but non-functional	Rectified
3.	Hose reel & down comer system are provided but non-functional	Rectified
4.	Exit signages are not provided	Not yet rectified

In view of the above, the application for issuance Fire Safety Certificate is not granted & rejected. The occupancy of the building/premises in absence of requisites fire safety measures shall be at the risk and liabilities of the owner/occupier. The Licensing Authority/statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

  
(Atul Garg)  
Director  
Delhi Fire Service  
08/05/23

Copy to:-

1. The Owner/occupier, M/s. Miraco Ventures Private Limited, G-4, First Floor, Pushkar Enclave, Paschim Vihar, New Delhi-110063.
2. The Deputy Health Officer, Keshav puram Zone, North DMC, A-1, Keshav puram, New Delhi.