



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7/5  
आजादी का  
अमृत महोत्सव

No.F6/DFS/MS/GH/SZ/2023/ 198

Dated: 09/05/2023

To

The Joint Commissioner of Police (Licensing),  
1st Floor, Police Station,  
Defence Colony, New Delhi.

**Sub:- Regarding grant of Fire Safety Certificate in r/o M/s MRK Guest House located at Plot no. 131, Pocket-2, Jasola, New Delhi-25.**

Sir,

With reference to the online application no. 2023032804406 dated 11.04.2023 on the subject cited above, it is informed that the building was inspected by Assistant Divisional Officer (M. Road) from this department on 24.04.2023 in the presence of Mrs. Nupur (Owner Daughter) and it was observed that the building is comprised of Basement + Stilt + ground + 3 upper floors. During the inspection following shortcomings were observed:-

1. Staircase width of 1.50 meters each must be provided.
2. Fire check door (FCD) not provided in basement.
3. Hose reels found not functional.
4. CO detectors in the common areas to be provided.
5. Automatic sprinkler system found not functional in basement.
6. Fire pumps found not functional.
7. Ext sinages found not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)

Director

Delhi Fire Service

o/c  
09/5