



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

C-59
7/5
आपत्ती व
अग्न महोत्सव

No. F6/DFS/MS/GH/SZ/2023 / 182

Dated: 27/04/2023

To

The Joint Commissioner of Police (Licensing),
1st Floor, Police Station Defence Colony,
New Delhi.

Ref: Online Application no. 2023040305017

Sub: Regarding Validation of Fire Safety Certificate in r/o M/s Nancee Guest House located at Plot no. - 49, Pocket-I, Jasola, New Delhi-14.

Sir,

With reference to the online application no. 2023040305017 dated 03.04.2023 on the subject cited above, it is informed that the said guest house was re-inspected by the ADO, M. Road on 13.04.2023 in the presence of Mr. Shahzad (Receptionist) and it was observed that other applicable requirements of clause 7.31, UBBL 2016 were found provided, some shortcomings listed below were observed at the time of inspection:

1. Carbon monoxide (CO) detector found non functional.
2. Hose reels found non functional.
3. Fire pump found non functional.
4. Kitchen found operational at still floor. The use of stilt floor is not as per the approved building plan.
5. One staircase of the basement found removed should be provided.

In view of the shortcomings, the FSC issued vide letter no. F6/DFS/MS/GH/2021/SZ/50 dated 01.02.2021 stands suspended and application no. 2023040305017 stands rejected.

Yours faithfully,

(Atul Garg)
Director

Delhi Fire Service

etc

Copy to:

1. The Licensee, M/s Nancee Guest House located at Plot no. - 49, Pocket-I, Jasola, New Delhi-14.