



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE; NEW DELHI- 110001



No.F6/DFS/MS/School/2023/ 235

Dated 04/05/2023

To

The Principal
 Nigam Pratibha Vidyalaya,
 M.C.D Colony, Azadpur, Delhi-110033.

Sub: Regarding issuance of fire safety certificate in r/o Nigam Pratibha Vidyalaya (School ID No- 1253127) located at M.C.D Colony, Azadpur, Delhi-110033.

Sir,

Please refer to your letter no. Nil dated 17.04.2023 received in this office vide outdoor dairy no.607 dated 17.04.2023 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 28.4.2023 to verify the fire safety measures issued vide Director of Education Circular dated 17.01.2005 and observed that the building was comprised of ground plus 02 upper floors only. At the time of inspection Smt. Reshma (Principal) was also present at site. During the course of inspection observations/ shortcomings made are as under:-

- 1 Hose reel hose provided but not functional and damaged condition.
- 2 Terrace level fire fighting pump capacity of 450lpm provided but not functional & damaged condition and jockey pump 180 lpm also not provided.
- 3 Terrace level fire water tank capacity of 2,000ltrs provided against the requirement of 10,000ltr.
- 4 Exit signage not provided at strategic locations in the school building.

Keeping in view of above, fire safety certificate cannot be considered at this stage.

Yours faithfully

(Atul Garg)

Director

Ph:-011-23414000

Copy to :-

1. The Director of Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.