

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No. F.6/DFS/MS/NDZ/2023/ 220

Dated: 04/05/2023

To

The Manager,
Punjab Grill (A unit of Delhi Photo Company),
78, Janpath, Connaught Place, New Delhi.

Subject:- Regarding issuance of FSC in r/o M/s Punjab Grill (A unit of Delhi Photo Company) at 78, Janpath, Connaught Place, New Delhi.

Sir,

This has a reference to online application ID No. Online id 2023040605474 dated 06.04.23, on the subject cited above. In this connection, it is to inform you that the site was visited on dated 02.04.23 by the officers concerned of this department in presence of **Manager** and following shortcomings are observed.

1. Pump is not provided with auto start provision.
2. The building plan as uploaded on the portal does not match with actual site. Moreover, seating arrangements have been shown on the mezzanine floor plan instead of storage, whereas application is for ground floor only for restaurant purpose.

In view of above, the Fire safety certificate cannot be issued. Therefore, you are requested to rectify the above shortcomings at the earliest for further consideration in the matter.

Yours faithfully,



(Atul Garg)
DIRECTOR
Delhi Fire Officer

Copy to :-

The Jt. Commissioner of police (Lic) 1st Floor , Defense colony police station , New Delhi