

c 22

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No: F.6/DFS/MS/School/2023/WZ/ 214

Dated: 02/05/2023

To,
The Principal,
Satyawati Shiksha Niketan,
Tigipur Road, Bakhtawarpur,
Delhi-110036.

Sub: - Regarding renewal of Fire Safety Certificate in r/o Satyawati Shiksha Niketan, Tigipur Road, Bakhtawarpur, Delhi-110036.

Sir,

This has reference to your letter no. nil received via outdoor diary no. 12537 dated 23.03.2023 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by officer concerned of this department on 20.04.2023 to see the compliance of the requisite fire safety measures. Sh. Kuldeep Sharma (Manager) was present at the time of inspection.

During the course of inspection it was observed that school building comprised of Ground and First Floor. Your request for renewal of FSC is rejected as the following shortcomings were observed:-

1. First Aid Hose Reel provided but not functional
2. Terrace level pump provided but not functional.
3. Overhead tank found detached from pump line.

You are advised to rectify the above-mentioned shortcoming for taking further action as necessary for renewal of Fire Safety Certificate.

Yours Faithfully

(Atul Garg)

Director

Ph. 011-23414000

our

Copy to:-

1. Director of Education, Govt. Of NCT of Delhi, Old Secretariat, New Delhi.