

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

C 21

No: F.6/DFS/MS/School/2023/WZ/ 236

Dated: 09/05/2023

To,

The Principal,
SRP Public School,
Laxmi Vihar, Prem Nagar-III,
Nangloi, Delhi-110041.

Sub: - Regarding issuance of Fire Safety Certificate in r/o SRP Public School located at Laxmi Vihar, Prem Nagar-III, Nangloi, Delhi-110041.

Sir,

This has reference to your letter no. SRP//01/2022-23 dated 20/03/2023 received via outdoor diary no. 12433 dated 21.03.2023 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by officer concerned of this department on 20.04.2023 to see the compliance of the requisite fire safety measures. Sh. Virender Dabas (Manager) was present at the time of inspection. During the course of inspection it was observed that school building comprised of Ground and Two Upper Floors. Your request for issuance of FSC is rejected as the following shortcomings were observed:-

1. Gate width found 3.40 m against required width of 4.5 m.
2. Width of staircase found 1.50 m & 1.15 m against the required width of 1.50 m each.
3. Door width found 1.10 m against the required width of 1.20m.
4. Fire Extinguishers provided but not functional.
5. First Aid Hose Reel provided but not functional.
6. Terrace level pump of 450 lpm capacity not provided.
7. An overhead tank of 10,000 ltrs capacity not provided.
8. Exit signage's not provided.

You are advised to rectify the above-mentioned shortcoming for taking further action as necessary for issuance of Fire Safety Certificate.

Yours Faithfully


(Atul Garg)
Director

Ph. 011-23414000



Copy to:-

1. Director of Education, Govt. Of NCT of Delhi, Old Secretariat, New Delhi.